



ELECTRICAL PERMIT APPLICATION

VILLAGE OF RIVER GROVE

2621 THATCHER AVE, RIVER GROVE IL 60171

DAVID B. GUERIN, PRESIDENT

PHONE 708-453-8007 FAX 708-453-1337

PERMIT NUMBER _____

DATE ISSUED ___/___/___

APPROVED FEE \$ _____

DATE: _____

BUILDING ADDRESS: _____ RIVER GROVE, 60171

BUILDING OWNER: _____ PHONE: _____

CONTRACTOR NAME: _____ PHONE: _____

CONTRACTOR ADDRESS: _____

MUNICIPALITY WHERE REGISTERED: _____ REG NUMBER: _____

SUPERVISING ELECTRICIAN SIGNATURE: _____

COST OF INSTALLATION: \$ _____

START DATE: _____ COMPLETION DATE: _____

NEW SERVICE: VOLTAGE: _____ AMPS: _____ PHASE: WIRE: _____

NUMBER OF METERS: _____

CIRCUITS: 15 AMP _____ POLE _____ 20 AMP _____ POLE _____
30 AMP _____ POLE _____ 50 AMP _____ POLE _____

LIST NUMBER OF MOTORS OR OTHER CURRENT CONSUMING DEVICES: _____

DESCRIPTION OF WORK: _____

PERMIT APPROVED BY: _____ DATE: _____

IMPORTANT NOTICE

1. THE PERMIT ISSUED ON THIS APPLICATION WILL AUTHORIZE ONLY WORK SPECIFIED. CONTRACTOR MUST GIVE COMPLETE INFORMATION AS INDICATED ON PERMIT APPLICATION
2. A PERMIT SHALL BE OBTAINED FOR ALL INSTALLATIONS OR ALTERATIONS OF ELECTRIC EQUIPMENT
3. A PERMIT SHALL BE OBTAINED **BEFORE THE WORK IS STARTED**
4. PERMITS WILL BE ISSUED TO THE ELECTRICAL CONTRACTORS ONLY WHEN THEY ARE REGISTERED IN CONFORMITY WITH THE ORDINANCES OF **THE VILLAGE OF RIVER GROVE**
5. APPLICATION FOR PERMIT SHALL GIVE THE LOCATION BY STREET AND NUMBER.
6. APPLICATION SHALL BE SIGNED BY THE REGISTERED CONTRACTOR AND BY THE SUPERVISING ELECTRICIAN
7. THE INSPECTION FEE MUST BE PAID BEFORE A PERMIT IS ISSUED. AS THIS FEE IS BASED ON THE APPARATUS INSTALLED **A CORRECT STATEMENT** OF SUCH APPARATUS SHALL APPEAR ON THE APPLICATION
8. CONTRACTOR SHALL NOT MAKE CONNECTION TO EXISTING WIRING WHERE SAME IS DEFECTIVE.
9. IN ALL CASES CONTRACTOR INSTALLING APPARATUS IN ADDITION TO EXISTING LOAD SHALL BE HELD RESPONSIBLE FOR ANY OVERLOAD OF SERVICE, BRANCH MAINS OR CIRCUITS
10. NO CURRENT SHALL BE USED ON APPARATUS INSTALLED UNDER AUTHORITY OF A PERMIT UNTIL THE ISSUANCE OF A TEMPORARY OR FINAL CERTIFICATE
11. WHEN THIS INSTALLATION IS READY FOR CURRENT A REQUEST FOR CURRENT SHALL BE MADE ON THE FORM PROVIDED FOR THIS PURPOSE. THE REQUEST FOR CURRENT SHALL IN ALL CASES, BE SIGNED BY SOME REPRESENTATIVE OF THE REGISTERED CONTRACTOR
12. A VIOLATION OF THE ORDINANCE OF THE VILLAGE OF RIVER GROVE GOVERNING THE INSTALLATION AND ALTERATION OF ELECTRICAL EQUIPMENT IS PUNISHABLE BY A FINE.

CALL  BEFORE YOU DIG. DIAL 811 OR 1-800-892-0123

VILLAGE OF RIVER GROVE

ADDITIONS TO THE ADOPTED CHICAGO ELECTRICAL CODE

7-7-7: ADDITIONS: Irrespective of any language in the Code hereby adopted to the contrary, the following regulations shall be applicable:

- (A) Commercial or industrial services shall be installed in rigid galvanized metal conduit, intermediate Galvanized metal conduit or by materials designed for the installation. Rigid aluminum conduit may be approved. Service equipment size shall be determined by the projected load. Derating of service conductors is not allowed.
- (B) Commercial and industrial service equipment shall be a minimum of 100 amperes with twenty-four (24) available circuits; switchboards and panel boards shall be of copper construction designed for use with bolt-on circuit breakers only; stab-in breakers or panels designed for use with a combination of stab-in and bolt-on circuit breakers are not permitted.
- (C) Main disconnects (circuit breakers) shall be provided in all panels installed for remodeling, replacement or new construction; all sources of power must be able to be turned off at the panel location. (Ord. 1996-06, 12-19-1996)
- (D) A minimum of 100 ampere service shall be provided for all single family residences. (20 circuit maximum)
- (E) The use of aluminum wire is not permitted.
- (F) All receptacle outlets within six feet (6') from a water faucet shall be protected by an approved ground fault circuit-interrupter. (Ord. 1 997-12, 11-6-1997)
- (G) Mogul fittings required on all service entrance conduits.
- (H) Grounding bushings required on all service conduits.